

Enclosure 7
Fire Safety Certificate



**Precision
Safety
Controls Pvt. Ltd.**

Fire Protection Engineers
License Agency of Maharashtra Fire Services



We are ISO 9001:2015 & ISO 45001:2018

- Fire System Installation
- Fire System Training
- Access Control System
- Time Attendance System
- Fire Audit Survey
- CCTV System
- P. A. System
- Annual Maintenance Contract
- Sales & Service
- Fire Extinguisher
- Refilling & Testing
- Fire Door

FORM- B

[See section 3(3) and rule 4(2)]

CERTIFICATE

Ref: PSCPL-B/2025-2026/313/KMC

Date: 10/01/2026

Certified that we have carried out inspection of the fire prevention and Life Safety Measures installed in the following premises.

M/s. DR. G. D. POL Foundation, Institutional Area, Sector 4, Kharghar, Navi Mumbai.

We Further certify that these installation in the above-mentioned buildings are maintained in good repair and efficient conditions during the period 1st July 2025 to 31st December 2025 as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection of installations carried out by me/us are mentioned in the report appended herewith.

Thanks & Regards,

M/s. Precision Safety Controls Pvt. Ltd.

SANDEEP ANANT KADAM
Digitally signed by
SANDEEP ANANT
KADAM
Date: 2026.01.10
15:05:25 +05'30'

**Mr. Sandeep Kadam
Licensed Agency (Directorate of you
Maharashtra Fire Service)
Government of Maharashtra
License No. MFS/LA/RF-85/RD-80/RP-24**

**VD. SANJEEV YADAV
PRINCIPAL
Dr. G. D. POL FOUNDATION
Y.M.T. AYURVEDIC MEDICAL COLLEGE AND HOSPITAL
Institutional Area Sector - 4,
Kharghar, Navi Mumbai - 410 210..**



CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SOC - 014874)

CIDCO/FIRE/HQ/2026/24

Date:- 23/01/2026

To,
M/s. G. D. Pol Foundation
Sector - 04, Kharghar,
Navi Mumbai

SUBJECT: Acceptance of Form "B".

- REFERENCE: 1) Online Application no. CIDCO-1769093132**
dt. 22/01/2026.
2) Form B Fees Paid Rs. 4500/- Receipt no.
6100005336/2025 dt. 20/01/2026.
3) Inspection Dt. 19/01/2026

Dear sir/madam,

As per section 3(3) of Maharashtra Fire Prevention & Life Safety Measures Act 2006, (Amended 2023), Form B submitted by M/s. G. D. Pol Foundation , Sector -04 , Kharghar , Navi Mumbai From Licensed Agency M/s Precision Safety Controls Pvt. Ltd. for the period of 1st July 2025 to 31st December 2025 is hereby accepted. The Installed Fixed Fire Fighting System was found in Good working condition on the day of Inspection. However It is responsibility of owner/occupier of the premises to maintain the fire fighting installations In good working condition all the time.

**VIJAY
SHANTARAM
RANE**

Digitally signed by VIJAY
SHANTARAM RANE
Date: 2026.01.23
13:35:31 +05'30'
CHIEF FIRE OFFICER
CIDCO FIRE SERVICES



V.D. SANJEEV YADAV
PRINCIPAL

Dr. G. D. POL FOUNDATION

Y.M.T. AYURVEDIC MEDICAL COLLEGE AND HOSPITAL

Regd. Office: Navi Mumbai Institutional Area Sector - 04, Kharghar - 400 021 • Tel: 022 6650 0900
Head Office: CIDCO Kharghar, Navi Mumbai - 400 614 • Tel: 022 6791 8100

Website: www.cidco.maharashtra.gov.in


V.D. SANJEEV YADAV
PRINCIPAL
Dr. G. D. POL FOUNDATION
Y.M.T. AYURVEDIC MEDICAL COLLEGE AND HOSPITAL
Institutional Area Sector - 04,
Kharghar, Navi Mumbai - 400 210.

Annexure


Ref: PSCPL-B/2025-2026/313/KMC

Date: 10/01/2026

M/s.DR. G. D. POL Foundation, Institutional Area, Sector 4, Kharghar,
Navi Mumbai.

Sr.No.	Item Description	Qty	Unit
A	Fire Hydrant System		
1	Booster Pump	6	Nos
2	Hose Reel With Shut-Up Nozzle	36	Nos
3	Inlet Connection	2	Nos
4	Overhead Tank	6	Nos
5	Wet Riser-Cum-Down System	6	Nos
6	Landing Valve	36	Nos
7	Metal Hose Box	15	Nos
8	RRL Type Hose	15	Nos
9	Gun Metal Nozzle	15	Nos
10	Underground Tank	2	Nos
11	Electric Pump	4	Nos
12	Jockey Pump	2	Nos
13	Courtyard Hydrant	10	Nos
14	Siamese Connection	2	Nos

SANDEEP ANANT KADAM
Digitally signed
by SANDEEP
ANANT KADAM
Date: 2026.01.10
15:03:20 +05'30'


VD. SANJEEV YADAV
PRINCIPAL
Dr. G. D. POL FOUNDATION
Y.M.T. AYURVEDIC MEDICAL COLLEGE AND HOSPITAL
Institutional Area Sector - 4,
Kharghar, Navi Mumbai - 410 210.



Govt. of Maharashtra
Directorate of Maharashtra Fire Service
 Vidyanaagri, Hans Bhugra Marg, Santacruz (East),
 Mumbai - 400 098, Tel-022-26877555, Fax-022-26877666
 www.mahafireservice.gov.in

FORM N
 [(See section 9 (3) and rule 14)
License to act as a License Agency for the purpose of
Fire Prevention and Life Safety Measure

License No. MFS / LA / RF-85 / RD-80/ RP-24

Date: 03.02.2024

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2008 (Mah. III of 2007) to **M/s. Precision Safety Controls Pvt Ltd.**, having their registration office at **Directorate of Maharashtra Fire Service** and their contact details are Office Number: 9987094270 and Email ID: info@pscontrols.co.in with PAN registration No. AAKCP7196H and GST No. 27AAKCP7196H1ZS to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Fire Fighting and Sprinkler System: **Class A**
- 2. Detection and Fire Suppression System: **Class C**
- 3. Passive System: **Class D**

M/s. Precision Safety Controls Pvt Ltd., shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **03.02.2024 to 02.02.2026**

Hatyal
 Kiran
 Asst Director

Digitally signed by Hatyal Kiran Date: 2024.03.08 21:51:35 +05'30'

**SANDEEP
 ANANT
 KADAM**

Digitally signed by Sandeep Anant Kadam Date: 2024.03.08 21:51:35 +05'30'

Santosh
 Shridhar
 Warick

Digitally signed by Santosh Shridhar Warick Date: 2024.03.08 22:41:30 +05'30'

(S S Warick)
 Director

Maharashtra Fire Service
 PRINCIPAL

Digital Signature of Authorized Person to sign Form A or Form B

Dr. G. D. POL FOUNDATION
 Y.M.T. AYURVEDIC MEDICAL COLLEGE AND HOSPITAL
 Institution of Area Sector - 4
 Kharghar, Navi Mumbai - 410 200.

Note:

* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.